


EC DECLARATION OF CONFORMITY	CE	
	YEAR	2013
	Ceramiche Settecento Valtresinaro S.p.A. Via del Crociale, 21 41041 Fiorano Modenese (MO) - Italy	

Declare that:

The product “**Wall finish and flooring tile, series Primitive**”, is in conformity with the provisions of the **ANNEX ZA and ZB** of **EN 14411** Ceramic tiles – Definitions, classifications, characteristic and marking.

Description and use of the product: Dry pressed tiles, glazed, group Bla, in conformity to EN 14411 annex G (only for first choice), for internal and external floorings and wall finishes.

Provisions to which the product conforms:

Characteristics	Declared Values	Notes/Test methods
Reaction to fire	A1	Without testing (See Decision 96/603/EC as amended)
Flexural tensile strength	Average R=49,7 (R>35N/mm ²)	EN ISO 10545.4
Bond strength / adhesion	NPD	This characteristic is under the responsibility of the person in charge of the execution of the tiling
Slipperiness	R9	DIN51130
	A	DIN51097
	NPD	B.C.R.A.
Skid resistance	NPD	---
Thermal shock resistance	Resistant	EN ISO 10545.9
Release of dangerous substances Release of cadmium Release of lead	NPD	EN ISO 10545.15
Durability: Freeze / thaw	Resistant (No damage after 100 cycles +5°/-5°)	EN ISO 10545.12

Name and address of involved laboratories:

Main Laboratory Sassuolo S.r.l., via P. Nenni, 7- 42019 Scandiano (RE)